

COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

CHRISTIAN COUNTY WATER DISTRICT'S)	
PROPOSED EXTENSION TO COLLINS BRIDGE)	
ROAD AND THE PROVISION OF SERVICE TO)	CASE NO. 90-220
CERTAIN CUSTOMERS WHO ARE CURRENTLY)	
SERVED BY SOUTH HOPKINS WATER DISTRICT)	

O R D E R

By letter received March 15, 1991, Christian County Water District ("CCWD") requested a deviation from 807 KAR 5:066, Section 11(2)(a), which limits the maximum length of small diameter water mains. CCWD has requested Commission approval to operate a 2-inch water line in excess of the maximum length allowed by regulation.

The Commission, having reviewed the letter and being otherwise sufficiently advised, finds that:

1. CCWD has acquired a 2-inch water main in excess of the length allowed by Commission regulation.

2. Hydraulic calculations submitted by CCWD's engineer indicate that pressure problems will not occur as a result of the 2-inch water main at this time. CCWD should be allowed to operate this 2-inch water main as long as adequate and reliable service can be provided in accordance with Commission regulations.

3. If the level of service on this 2-inch water main is inadequate or declining, or the pressure is outside the requirements of 807 KAR 5:066, Section 6(1), CCWD should take necessary actions to maintain the level of service in conformance with Commission regulations.


IT IS THEREFORE ORDERED that:

1. CCWD be and it hereby is granted a deviation from 807 KAR 5:066, Section 11(2)(a), and granted permission to operate a 2-inch water line which length exceeds the maximum length allowed by Commission regulations. The approval of the operation of this line which serves State Highway 1338 is contingent upon adequate and reliable service being provided in compliance with Commission regulations.


2. CCWD shall monitor the adequacy of this line extension. If the level of service on this extension is inadequate or declining, or the pressure is outside the requirements of 807 KAR 5:066, Section 6(1), CCWD shall take necessary actions to maintain the level of service in conformance with Commission regulations.

Done at Frankfort, Kentucky, this 10th day of April, 1991.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director